

**CPRI**

**TEST REPORT**



**Central Power Research Institute**

**(A Govt. of India Society)**

**P.B.No. 8066, Sadashivanagar Post Office,  
Sir C.V. Raman Road,  
Bangalore - 560 080 (INDIA)**



CPRI

SHORT CIRCUIT LABORATORY  
CENTRAL POWER RESEARCH INSTITUTE  
(Member of STL)

P.B.NO.8066, SADASHIVANAGAR POST OFFICE  
SIR C.V.RAMAN ROAD, BANGALORE - 560 080 (INDIA)  
Phone: +91 (0) 80 - 23602662 Fax : +91 (0) 80 - 23601213



T-0010  
Sheet 1 of 4

TEST REPORT

<b>Test Report Number</b>	SC09617P	<b>dated:</b> 4 <sup>th</sup> November, 2009
<b>Name &amp; Address of the Customer</b>	M/s. Krishnaa Energy Private Limited, DP:69, SIDCO Industrial Estate, Thirumudivakkam, Chennai - 600 044	
<b>Name &amp; Address of the Manufacturer</b>	M/s. Krishnaa Energy Private Limited, DP:69, SIDCO Industrial Estate, Thirumudivakkam, Chennai - 600 044	
<b>Particulars of sample tested</b>	11 kV Current Transformer	
<b>Condition of the sample on Receipt</b>	New	
Type	Indoor, resin cast	
Designation	---	
Serial Number	016 / 09	
Number of samples tested	One	
Date (s) of test (s)	23 <sup>rd</sup> September, 2009	
CPRI sample code no(s).	SC09S1824	
<b>Particulars of tests conducted</b>	Temperature-Rise	
Test in accordance with Standard / specification	Sub-clause 9.7 of IS 2705 (Part 1): 1992 (Reaffirmed 2002)	
Sampling plan	Not applicable	
Customer's requirement	None	
Deviations if any	Nil	
<b>Name of the witnessing persons</b>		
Customer's representative	Mr. K. S. Suresh Kumar, Manager - Production	
Other than customer's representative	None	
Test subcontracted with address of the laboratory	None	
<b>Documents constituting this report (In words)</b>		
Number of sheets	Four	
Number of oscillograms	Nil	
Number of graphs	Nil	
Number of photos	Nil	
Number of test circuit diagrams	Nil	
Number of drawings	One	

  
(Nagananda)  
Test Engineer



  
(B. R. Ravishankar)  
Joint Director



CPRI

**SHORT CIRCUIT LABORATORY  
CENTRAL POWER RESEARCH INSTITUTE  
(Member of STL)**

P.B.NO.8066, SADASHIVANAGAR POST OFFICE  
SIR C.V.RAMAN ROAD, BANGALORE - 560 080 (INDIA)  
Phone: +91 (0) 80 - 23602662 Fax : +91 (0) 80 - 23601213



T-0010  
Sheet 2 of 4

Report Number: SC09617P

**Description of sample tested (rating as assigned by the manufacturer)**

Tested sample	Current Transformer	
Type	Indoor, Resin cast	
Designation	WPL CT	
Serial number	016/09	
Nominal system voltage	11 kV	
Highest system voltage	12 kV	
Rated insulation level	28 kV rms / 75 kV peak	
Frequency	50 Hz	
No. of cores	I	II
Accuracy class	0.5	5P
Rated output-VA	15	15
Rated Transformation Ratio	150/5 A	150/5 A
Accuracy limit factor	---	10
Rated short-time withstand current & peak withstand current	25 kA rms for 3.0 seconds & 62.5 kA peak	
<b>Winding details</b>		
Primary	2 Turns of Electrolite Copper strips of size 20 X 1 sq. mm Twelve numbers in parallel (240 sq. mm) covered with Polyester film and Polyester tape	
Secondary		
Core 1	60 Turns of 18 SWG Super enamelled Copper conductor - Three numbers in parallel	
Core 2	60 Turns of 14 SWG Super enamelled Copper conductor.	

**Documents attached to this report**

Drawing number (s) KEPL-11RCT-001 SHT. No. 1 OF 1 REV.0

Test Engineer



CPRI

SHORT CIRCUIT LABORATORY  
CENTRAL POWER RESEARCH INSTITUTE  
(Member of STL)

P.B.NO.8066, SADASHIVANAGAR POST OFFICE  
SIR C.V.RAMAN ROAD, BANGALORE - 560 080 (INDIA)  
Phone: +91 (0) 80 - 23602662 Fax : +91 (0) 80 - 23601213



T-0010

Sheet 3 of 4

Report Number: SC09617P

Schedule of test

TEMPERATURE-RISE TEST

**Test conditions**

Ambient temperature : 25.5°C  
Test current : 180 A

**External Connections**

Primary winding : 50 sq. mm. PVC insulated copper conductor of 1.0 metre length  
Secondary winding : A burden of 0.6 Ω with unity power factor

**Test results**

**a. Temperature rise of secondary windings (by resistance method):**

Parts	Temperature-rise (K)	Limit (K)
Secondary (1S1-1S2)	6.32	80
Secondary (2S1-2S2)	7.30	80

**b. Temperature rise in other parts:**

Ambient temperature: 26.7°C



Parts	Temperature-rise (K)	Limit (K)
Primary terminal (P1)	8.2	80
Primary terminal (P2)	9.2	80
Secondary terminal (1S1)	3.3	80
Secondary terminal (1S2)	2.4	80
Secondary terminal (2S1)	3.7	80
Secondary terminal (2S2)	3.3	80
Body	3.3	--

**Remarks:** The sample tested complies with the sub-clause of the standard referred to.

*Ragunanda*  
Test Engineer

THIS DRAWING IS THE PROPERTY OF KRISHNAA ENERGY PRIVATE LIMITED AND MUST NOT BE COPIED OR REPRODUCED WITHOUT THEIR CONSENT.

THE POLICY OF KRISHNAA ENERGY IS CONTINUAL IMPROVEMENT & DEVELOPMENT.





TECHNICAL DETAILS	
Epoxy Resin Cast, Post Type, Current Transformer, Indoor Panel Mounting, Class B	
Primary Current	: 150 A
Secondary Current	: 5-5A
Insulation level	: 12/28/75 Kv
Frequency	: 50 Hz
1 Thermal (Short time Rating)	: 25 kA / 3 sec
1 Dynamic	: 2.5 Times
Standard	: IS2705 Part I & II

कें. वि. अ. सं. द्वारा इस रेखाचित्र का सत्यापन जहाँ कहीं भी संभव हो सिर्फ विमीय जाचें तक ही सीमित है।  
 THE VERIFICATION OF THIS DRAWING BY CPRI IS LIMITED TO DIMENSIONAL CHECKS ONLY WHEREVER POSSIBLE

CURRENT TRANSFORMER	
RATIO	: 150 / 5-5A
SYSTEM VOLTAGE	: 11 KV
ILV	: 12/28/75
STR	: 25 KA/ 3 SEC
SL.NO.	: 016/09
BURDEN	: CORE I : 15 VA/CL 0.5 CORE II : 15 VA/CL 5p10
FREQ.	: 50 Hz
IS2705/1992/IEC	: 60044-1
MFD. BY:	KRISHNAA ENERGY PVT LTD., CHENNAI - 44

रिपोर्ट क्रमांक.....  
 से संबंधित दस्तावेज  
 Document Pertaining to  
 Report No.: SC09617P



**WINDING DETAIL'S:**  
**Primary Winding :-**  
 2 - Turns 20x1 (240Sq.mm) Electrolyte Copper strip 12 in parallel.  
 Covered with Polyester Film & Polyester Tape  
**Secondary Windings:-**  
 Metering :- 60 Turns, 18 swg 3 in Parallel Super Enameled Copper Conductor.  
 Protection :- 60 Turns, 14 swg single Parallel Super Enameled Copper Conductor.

परीक्षण अभियन्ता / Test Engineer  
 ल.प. प्रयोगशाला / S. C. LAB  
 सी. पी. आर. आई. / CPRI  
 बंगलूरु / Bangalore

TYPE: INDOOR RESIN CAST		QTY: -		ALL DIMENSION ARE IN mm		TITLE: 11 KV WOUND PRIMARY CURRENT TRANSFORMER	
0		BJM	K.S.S.KK.S.S.K		21/9/09	MFG BY: Krishna	
REV.	DATE	DESCRIPTION	DRAWN	CHD.	APPD.	SIGN	DATE.
CUSTOMER : -							

MFG BY: KRISHNAA ENERGY PRIVATE LIMITED.,  
 DP:69, SIDCO Industrial Estate, Thirumudivakkam, Chennai-44  
 www.krishnaenergy.net

Alliance Partner of for MV Components Integration

SCALE : NTS	
SHT.No.	DRAWING No.
1 OF 1	KEPL-11RCT-001



**CPRI**

**SHORT CIRCUIT LABORATORY  
CENTRAL POWER RESEARCH INSTITUTE  
(Member of STL)**

P.B.NO.8066, SADASHIVANAGAR POST OFFICE  
SIR C.V.RAMAN ROAD, BANGALORE - 560 080 (INDIA)  
Phone: +91 (0) 80 - 23602662 Fax : +91 (0) 80 - 23601213



T-0010

Sheet 4 of 4

**Report Number: SC09617P**

**NOTE**

- a) This is not a certificate of rating. A certificate of rating is not issued as only limited tests as requested by the customer were carried out.
- b) The test results relate only to the item(s) tested.
- c) Publication or reproduction of this report in any form other than by complete set of the whole report and in the language written, is not permitted without the written approval of CPRI.
- d) Corrections / erasings invalidate the test report.
- e) Any anomaly / discrepancy in the test report should be brought to our notice within 45 days from the date of issue.

**Additional Information:**

CPRI issues following types of reports/certificates:

**Test Report:**

The test report contains the record of the values of test parameters as obtained during testing, the physical condition of the sample during / after the test(s) and copy of oscillogram(s). Test report is issued when partial tests are performed as against the complete test requirement for proving specific ratings.

**Sealed Certificate:**

The sealed certificate is issued, on request and payment of the prescribed charges thereof only when the sample of particular type and rating has satisfactorily passed all the specified tests in compliance with the condition stipulated in a published National / International standard.

**CPRI issues the following type test certificates based generally on STL Guidelines:**

- I. Type test certificate of Short Circuit Performance.
- II. Type test certificate of Switching Performance.
- III. Type test certificate of Temperature Rise Performance.
- IV. Type test certificate of Dielectric Performance.
- V. Type test certificate of complete type test.

  
Test Engineer